Ref. Certif. No.

NL-122193

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Industrial Rechargeable Lithium ion Battery System
Name and address of the applicant	Shenzhen Ruidian Green Energy Technology Co., Ltd. A801 Building 3ABCD, Cloud Park, Bantian, Longgang District, 518129 Shenzhen Guangdong, China
Name and address of the manufacturer	Shenzhen Ruidian Green Energy Technology Co., Ltd. A801 Building 3ABCD, Cloud Park, Bantian, Longgang District, 518129 Shenzhen Guangdong, China
Name and address of the factory	Ruidian Green Energy Technology (Huizhou) Co., Ltd. No.3 Donghua South Road, Dongjiang High-tech industrial park, Zhongkai High-tech industrial Development Zoon, 516001 Huizhou City, Guangdong, China
When more than one factory	☐ Additional information on page 2
Ratings and principal characteristics	**Product data** Nomibal capacity: 314 Ah **Product data – type CX-125/261-FP, CX-125/261-FP-Y, GM-261.2-HPB and UX-261.2-HPB** Rated voltage: 832,0 Vdc **Product data – type CX-215/418-FP-Y, GM-418.0-HPB and UX-418.0-HPB** Rated voltage: 1331,2 Vdc **Product data – type GM-52.2-HPB** Rated voltage: 166,4 V
Trademark / Brand (if any)	Absen
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	CX-125/261-FP, CX-125/261-FP-Y, CX-215/418-FP-Y, GM-261.2-HPB, GM-418.0-HPB, GM-52.2-HPB, UX-261.2-HPB and UX-418.0-HPB
Additional information	☒ Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62619:2022
As shown in the Test Report Ref. No. which forms part of this Certificate	4944618.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2025-12-12

Signature: Iris Lu

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional information

Model/Type reference:
GM-261.2-HPB/ UX-261.2-HPB/ CX-125/261-FP-Y/ CX-125/261-FP
GM-418.0-HPB/ UX-418.0-HPB/ CX-215/418-FP-Y
Battery Module: GM-52.2-HPB

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2025-12-12

Signature: Iris Lu