



PV Doctor: Inspection & Improving


The leading anti-PID proposal

PID Recovery System



Certification: CE (EN 61000) / CE (EN 62109) / IP65

ANTI-PID04-3



Data sheet

Item		ANTIPID04-3
Qty. of Inverter connecting with		3 (Capacity of each inverter ≤ 70 kW)
General Data	Operating Temperature (°C)	-25 ~ 65
	Operating Humidity (%RH)	≤ 95
	Dimension (mm)	360×260×103
	Weight (kg)	≤ 6
	Certification	CE
	Altitude (m)	≤ 4.000
Control Method	Control method	Clock / Module voltage
	Display	LED
	Operating	Button
DC Output	Voltage (V)	400 ~ 1000
	Voltage Resolution (V)	1
	Rated current (mA)	30
	Rated Power (W)	30
	Permit Insulating Resistance (KΩ)	≥ 6.6
AC Input	Voltage (V)	100 ~ 250
	Frequency (Hz)	50 / 60
	Ground Cable	Optional
Module Voltage (V)		0 ~ 1000
IP class		IP65
Communication (Optional)		RS-485 / Fault Relay
Warranty (Year)		2